

Basic Asset/Component Information													Financial Accounting Values				Condition / Performance and Risk Assessment Information										Comments & Changes to PSAB data	Infrastructure Assets Required to Improved System Performance
Asset Number	Category	Sub-Category	Department	Roll Number	Location	Class of Asset	Year of Acquisition	PSAB Useful Life	PSAB Remaining UL	Useful Life	Remaining Useful Life	Age	Historical Cost December 31, 2012	Accumulated Amortization December 31, 2012	Net Book Value December 31, 2012	Replacement Cost	Condition Rating	Method of Last Condition Assessment	Asset Conditions / Deficiencies	Probability of Failure	Consequence of Failure	Risk / Criticality	Critical Maintenance Activities / Immediate Replacement					
WWC-SPS-BAN-01	Buildings	Structure	Wastewater Collection	562705005600700.00	Bannerman & Cloutier Sewage Pumping Station	Pumping Station WELL	1965	4	0	60	12	48	\$ 1,747,222	\$ 1,123,420	\$ 623,802	\$ 22,265,000	3	Field Audit	Fair	2	4	8	Revised Class of Asset description	Install SCADA communication to improve operations & control of the station				
WWC-SPS-BAN-02	Mach/Equip	Heavy	Wastewater Collection		Bannerman & Cloutier Sewage Pumping Station	MCC	1978	20	0	20	0	35	\$ -	\$ -	\$ -	\$ 40,000	4	Field Audit	Fair	3	3	9	Added new asset class not on PSAB list					
WWC-SPS-BAN-03	Mach/Equip	Heavy	Wastewater Collection	562705005600700	Bannerman & Cloutier Sewage Pumping Station	Pump No. 1	2008	20	15	20	15	5	controlled asset	\$ -	controlled asset	\$ 25,000	2	Field Audit	Good	2	3	6	Corrected PSAB data that listed old pumps installed in 1978 instead of pumps replaced in 2008.					
WWC-SPS-BAN-04	Mach/Equip	Heavy	Wastewater Collection	562705005600700	Bannerman & Cloutier Sewage Pumping Station	Pump No. 2	2008	20	15	20	15	5	controlled asset	\$ -	controlled asset	\$ 25,000	2	Field Audit	Good	2	3	6						
WWC-SPS-BRU-01	Buildings	Structure	Wastewater Collection	562703003000602.00	Brundy & Delost Sewage Pumping Station	Pumping Station WELL	1977	40	4	60	24	36	Controlled Asset	\$ 8,013	Controlled Asset	\$ 50,000	2	Field Audit	Good	2	4	8	Revised Class of Asset description					
WWC-SPS-BRU-02	Mach/Equip	Heavy	Wastewater Collection	562703003000602	Brundy & Delost Sewage Pumping Station	Pump No. 1	2005	20	12	20	12	8	\$ 8,013	\$ 3,205	\$ 4,808	\$ 25,000	2	Field Audit	Good	2	3	6						
WWC-SPS-BRU-03	Mach/Equip	Heavy	Wastewater Collection	562703003000602	Brundy & Delost Sewage Pumping Station	Pump No. 2	2005	20	12	20	12	8	\$ 8,013	\$ 3,205	\$ 4,808	\$ 25,000	2	Field Audit	Good	2	3	6						
WWC-SPS-BRU-04	Mach/Equip	Heavy	Wastewater Collection		Brundy & Delost Sewage Pumping Station	MCC	2005	20	12	20	12	8	\$ -	\$ -	\$ -	\$ 40,000	2	Field Audit	Good	2	3	6	Added new asset class not on PSAB list					
WWC-SPS-CRO-01	Buildings	Structure	Wastewater Collection	562703003016302.00	Croatia Ave. Sewage Pumping Station	Pumping Station WELL and Generator Building	1965	40	0	60	12	48	Controlled Asset		Controlled Asset	\$ 40,000	2	Field Audit	Good	2	2	4	Revised Class of Asset description					
WWC-SPS-CRO-02	Mach/Equip	Heavy	Wastewater Collection	562703003016302	Croatia Ave. Sewage Pumping Station	Diesel Generator	1978	20	0	35	0	35	\$ 9,217	\$ 9,217	\$ -	\$ 40,000	3	Field Audit	Fair. Fuel tank in tight space with no spill containment	2	2	4						
WWC-SPS-CRO-03	Mach/Equip	Heavy	Wastewater Collection	562703003016302	Croatia Ave. Sewage Pumping Station	Pump No. 1	2005	20	12	20	12	8	\$ 8,013	\$ 3,205	\$ 4,808	\$ 25,000	2	Field Audit	Good	2	3	6						
WWC-SPS-CRO-05	Mach/Equip	Heavy	Wastewater Collection	562703003016302	Croatia Ave. Sewage Pumping Station	MCC Panel & Transfer Switch	2005	20	12	20	12	8	\$ 8,013	\$ 3,205	\$ 4,808	\$ 60,000	2	Field Audit	Good	2	3	6	Added new asset class not on PSAB list	Install SCADA communication				
WWC-SPS-FAT-01	Buildings	Structure	Wastewater Collection	562703003016100.00	Father Costello Sewage Pumping Station	Pumping Station WELL	1977	40	4	60	24	36	Controlled Asset		Controlled Asset	\$ 60,000	2	Field Audit	Good	2	4	8	Revised Class of Asset description					
WWC-SPS-FAT-02	Mach/Equip	Heavy	Wastewater Collection	562703003016100	Father Costello Sewage Pumping Station	Pump No. 1	2002	20	9	20	9	11	\$ 6,885	\$ 3,787	\$ 3,098	\$ 40,000	3	Field Audit	Fair. Rusted piping /electrical panels	2	3	6						
WWC-SPS-FAT-03	Mach/Equip	Heavy	Wastewater Collection	562703003016100	Father Costello Sewage Pumping Station	Pump No. 2	2002	20	9	20	9	11	\$ 6,885	\$ 3,787	\$ 3,098	\$ 40,000	3	Field Audit	Fair	2	3	6						
WWC-SPS-FAT-04	Mach/Equip	Heavy	Wastewater Collection		Father Costello Sewage Pumping Station	MCC	2002	20	9	20	9	11	\$ -	\$ -	\$ -	\$ 50,000	4	Field Audit	Fair	3	3	9	Added new asset class not on PSAB list	Install SCADA communication				
WWC-SPS-HUD-01	Buildings	Structure	Wastewater Collection	562701011542400.00	Hudson Crescent Sewage Pumping Station	Pumping Station WELL	1965	40	0	60	12	48	Controlled Asset		Controlled Asset	\$ 60,000	2	Field Audit	Good	2	4	8	Revised Class of Asset description					
WWC-SPS-HUD-02	Mach/Equip	Heavy	Wastewater Collection	562701011542400	Hudson Crescent Sewage Pumping Station	Pump No. 1	1998	20	5	20	5	15	\$ -	\$ -	\$ -	\$ 25,000	3	Field Audit	Fair	2	3	6						
WWC-SPS-HUD-03	Mach/Equip	Heavy	Wastewater Collection	562701011542400	Hudson Crescent Sewage Pumping Station	Pump No. 2	1998	20	5	20	5	15	\$ -	\$ -	\$ -	\$ 25,000	3	Field Audit	Fair	2	3	6						
WWC-SPS-HUD-04	Mach/Equip	Heavy	Wastewater Collection		Hudson Crescent Sewage Pumping Station	MCC	2013	20	20	20	20	0	\$ -	\$ -	\$ -	\$ 40,000	1	Field Audit	Good	1	3	3	Installed new Pump Control Panel in 2013. Added new asset class not on PSAB list	Install SCADA communication				
WWC-SPS-MOU-01	Buildings	Structure	Wastewater Collection	562705005802002.00	Industrial Park Sewage Pumping Station	Pumping Station Building	1986	40	13	60	33	27	\$ 61,227	\$ 41,328	\$ 19,899	\$ 120,000	2	Field Audit	Good	2	4	8	Revised Class of Asset description					
WWC-SPS-MOU-02	Mach/Equip	Heavy	Wastewater Collection	562705005802002	Industrial Park Sewage Pumping Station	Pump No. 1	1985	20	0	20	0	28	controlled asset	\$ -	controlled asset	\$ 25,000	3	Field Audit	Fair	2	3	6						
WWC-SPS-MOU-03	Mach/Equip	Heavy	Wastewater Collection	562705005802002	Industrial Park Sewage Pumping Station	Pump No. 2	1985	20	0	20	0	28	controlled asset	\$ -	controlled asset	\$ 25,000	3	Field Audit	Fair	2	3	6						
WWC-SPS-MOU-04	Mach/Equip	Heavy	Wastewater Collection		Industrial Park Sewage Pumping Station	MCC	1985	20	0	20	0	28	\$ -	\$ -	\$ -	\$ 40,000	3	Field Audit	Fair	2	3	6	Added new asset class not on PSAB list	Install SCADA communication				
WWC-SPS-MCI-01	Buildings	Structure	Wastewater Collection	562703009000700.00	McIntyre Sewage Pumping Station	Pumping Station WELL and Chamber	1965	40	0	60	12	48	\$ 51,929	\$ 51,929	\$ -	\$ 200,000	3	Field Audit	Fair	2	4	8	Revised Class of Asset description					
WWC-SPS-MCI-02	Mach/Equip	Heavy	Wastewater Collection	562703009000700	McIntyre Sewage Pumping Station	Pump No. 1	1978	20	0	35	0	35	\$ 5,761	\$ 5,761	\$ -	\$ 120,000	4	Field Audit	Fair	3	3	9						
WWC-SPS-MCI-03	Mach/Equip	Heavy	Wastewater Collection	562703009000700	McIntyre Sewage Pumping Station	Motor 2	1978	20	0	20	0	35	controlled asset	\$ -	controlled asset	\$ 40,000	4	Field Audit	Fair	3	3	9						
WWC-SPS-MCI-04	Mach/Equip	Heavy	Wastewater Collection	562703009000700	McIntyre Sewage Pumping Station	Flowmeter	1978	20	0	20	0	35	controlled asset	\$ -	controlled asset	\$ 20,000	4	Field Audit	Fair	3	1	3						
WWC-SPS-MCI-05	Mach/Equip	Heavy	Wastewater Collection	562703009000700	McIntyre Sewage Pumping Station	Pump No. 2	2004	20	11	20	11	9	\$ 19,026	\$ 8,562	\$ 10,464	\$ 120,000	2	Field Audit	Good	2	3	6						
WWC-SPS-MCI-06	Mach/Equip	Heavy	Wastewater Collection	562703009000700	McIntyre Sewage Pumping Station	Motor 1	2006	20	13	20	13	7	controlled asset		controlled asset	\$ 40,000	2	Field Audit	Good	2	3	6						
WWC-SPS-MCI-07	Mach/Equip	Heavy	Wastewater Collection		McIntyre Sewage Pumping Station	MCC	2012	20	19	20	19	1	\$ -	\$ -	\$ -	\$ 70,000	1	Field Audit	Good	1	3	3	Installed new Pump Control Panel & program in 2012. Added new asset class not on PSAB list	Install SCADA communication				
WWC-SPS-NOR-01	Buildings	Structure	Wastewater Collection	562701011505900.00	Norman Sewage Pumping Station	Pumping Station WELL	1965	40	0	60	12	48	Controlled Asset		Controlled Asset	\$ 50,000	2	Field Audit	Good	2	4	8	Revised Class of Asset description					
WWC-SPS-NOR-02	Mach/Equip	Heavy	Wastewater Collection	562701011505900	Norman Sewage Pumping Station	Pump No. 1	2010	20	17	20	17	3	\$ 8,517	\$ 1,278	\$ 7,240	\$ 25,000	1	Field Audit	Good	1	3	3						
WWC-SPS-NOR-03	Mach/Equip	Heavy	Wastewater Collection	562701011505900	Norman Sewage Pumping Station	Pump No. 2	2010	20	17	20	17	3	\$ 8,517	\$ 1,278	\$ 7,240	\$ 25,000	1	Field Audit	Good	1	3	3						
WWC-SPS-NOR-04	Mach/Equip	Heavy	Wastewater Collection	562701011505900	Norman Sewage Pumping Station	MCC	2010	20	17	20	17	3	\$ 9,452	\$ 1,418	\$ 8,034	\$ 30,000	1	Field Audit	Good	1	3	3	Revised Class of Asset description	Install SCADA communication				
WWC-SPS-PAR-01	Buildings	Structure	Wastewater Collection	562701011105100.00	Park Ave. Sewage Pumping Station	Pumping Station Building	1968	40	0	60	15	45	\$ 136,130	\$ 136,130	\$ -	\$ 1,200,000	4	Field Audit	Fair. Rusted roof over wet well. No Fence	3	4	12	Repair Rusted Roof and install fence within 1 year. Ventilation of the wet well area should be assessed to prevent roof rusting	Revised Class of Asset description	Install SCADA communication			
WWC-SPS-PAR-02	Mach/Equip	Heavy	Wastewater Collection	562701011105100	Park Ave. Sewage Pumping Station	Pump No. 3	1978	20	0	35	0	35	\$ 5,761	\$ 5,761	\$ -	\$ 150,000	4	Field Audit	Fair	3	3	9						
WWC-SPS-PAR-03	Mach/Equip	Heavy	Wastewater Collection	562701011105100	Park Ave. Sewage Pumping Station	Motor 1	1978	20	0	25	0	35				\$ 60,000	4	Field Audit	Fair	3	3	9						
WWC-SPS-PAR-04	Mach/Equip	Heavy	Wastewater Collection	562701011105100	Park Ave. Sewage Pumping Station	Motor 3	1978	20	0	25	0	35				\$ 60,000	4	Field Audit	Fair	3	3	9						
WWC-SPS-PAR-05	Mach/Equip	Heavy	Wastewater Collection	562701																								

Basic Asset/Component Information													Financial Accounting Values				Condition / Performance and Risk Assessment Information										Comments & Changes to PSAB data	Infrastructure Assets Required to Improved System Performance
Asset Number	Category	Sub-Category	Department	Roll Number	Location	Class of Asset	Year of Acquisition	PSAB Useful Life	PSAB Remaining UL	Useful Life	Remaining Useful Life	Age	Historical Cost December 31, 2012	Accumulated Amortization December 31, 2012	Net Book Value December 31, 2012	Replacement Cost	Condition Rating	Method of Last Condition Assessment	Asset Conditions / Deficiencies	Probability of Failure	Consequence of Failure	Risk / Criticality	Critical Maintenance Activities / Immediate Replacement					
WWC-SPS-ESS-02	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Pump No. 1	1978	20	0	35	0	35	Controlled Asset	Controlled Asset	Controlled Asset	\$ 240,000	5	Field Audit	Very Poor	4	3	12	Replace within 1 to 4 years					
WWC-SPS-ESS-03	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Pump No. 2	1978	20	0	35	0	35	Controlled Asset	Controlled Asset	Controlled Asset	\$ 240,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-ESS-04	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	By Pass Pump No. 3	1978	20	0	20	0	35	\$ 6,913	\$ 6,913	\$ -	\$ 120,000	5	Field Audit	Poor	4.0	2.0	8.0						
WWC-SPS-ESS-05	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	By Pass Pump No. 4	1978	20	0	20	0	35	\$ 6,913	\$ 6,913	\$ -	\$ 120,000	5	Field Audit	Poor	4.0	2.0	8.0						
WWC-SPS-ESS-06	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	By-Pass Pump No. 3 MOTOR	1978	20	0	20	0	35	Controlled Asset	Controlled Asset	Controlled Asset	\$ 50,000	5	Field Audit	Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-ESS-07	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	By-Pass Pump No. 4 MOTOR	1978	20	0	20	0	35	Controlled Asset	Controlled Asset	Controlled Asset	\$ 50,000	5	Field Audit	Poor	4.0	2.0	8.0						
WWC-SPS-ESS-08	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Diesel Generator	1978	20	0	20	0	35	\$ 6,913	\$ 6,913	\$ -	\$ 300,000	5	Field Audit	Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-ESS-09	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Flowmeter	1978	20	0	20	0	35	Controlled Asset	Controlled Asset	Controlled Asset	\$ 40,000	5	Field Audit	Poor	4.0	1.0	4.0						
WWC-SPS-ESS-10	Buildings	Structure	Wastewater Collection	562702005019900.00	Station No. 3 - Essa St	Pumping Station Building	1989	40	16	60	36	24	\$ 177,393	\$ 168,523	\$ 8,870	\$ 1,800,000	3	Field Audit	Fair	2.0	4.0	8.0		Revised Class of Asset description				
WWC-SPS-ESS-11	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Pump 2 VFD	1995	20	2	20	2	18	\$ 5,819	\$ 5,237	\$ 582	\$ 150,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-ESS-12	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Motor 1	1999	20	6	20	6	14	Controlled Asset	Controlled Asset	Controlled Asset	\$ 60,000	4	Field Audit	Poor	3.0	2.0	6.0						
WWC-SPS-ESS-13	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Motor 2	1999	20	6	20	6	14	Controlled Asset	Controlled Asset	Controlled Asset	\$ 60,000	4	Field Audit	Poor	3.0	3.0	9.0						
WWC-SPS-ESS-14	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Unwastering Pump	2003	20	10	20	10	10	\$ 5,712	\$ 2,856	\$ 2,856	\$ 40,000	3	Field Audit	Fair	2.0	1.0	2.0						
WWC-SPS-ESS-15	Mach/Equip	Heavy	Wastewater Collection	562702005019900	Station No. 3 - Essa St	Pump 1 VFD	2009	20	16	20	16	4	\$ 15,368	\$ 3,074	\$ 12,295	\$ 150,000	2	Field Audit	Good	2.0	3.0	6.0						
WWC-SPS-HWY-01	Buildings	Structure	Wastewater Collection	562704009000500.00	Station No. 4 - Hwy 101	Pumping Station Building	1975	40	2	60	22	38	\$ 77,203	\$ 73,343	\$ 3,860	\$ 1,000,000	4	Field Audit	Poor	3.0	4.0	12.0	Replace within 1 to 4 years	Revised Class of Asset description				
WWC-SPS-HWY-02	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	MCC	1977	20	0	20	0	36	\$ 4,317	\$ 4,317	\$ -	\$ 300,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-HWY-03	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Pump No. 1	1978	20	0	20	0	35	\$ 6,913	\$ 6,913	\$ -	\$ 250,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-HWY-04	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Motor 1	1978	20	0	20	0	35	Controlled Asset		Controlled Asset	\$ 80,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-HWY-05	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Diesel Generator	1978	20	0	20	0	35	\$ 11,521	\$ 11,521	\$ -	\$ 250,000	5	Field Audit	Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-HWY-06	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Motor 2	2002	20	9	20	9	11	Controlled Asset		Controlled Asset	\$ 80,000	3	Field Audit	Fair	2.0	3.0	6.0						
WWC-SPS-HWY-07	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Pump 2 VFD	2006	20	13	20	13	7	\$ 8,978	\$ 3,142	\$ 5,836	\$ 150,000	2	Field Audit	Good	2.0	3.0	6.0						
WWC-SPS-HWY-08	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Pump No. 2	2011	20	18	20	18	2	\$ 15,579	\$ 1,558	\$ 14,022	\$ 250,000	2	Field Audit	Good	2.0	3.0	6.0						
WWC-SPS-HWY-09	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	Pump 1 VFD	2011	20	18	20	18	2	\$ -			\$ 150,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years	Added new asset class not on PSAB list				
WWC-SPS-HWY-10	Mach/Equip	Heavy	Wastewater Collection	562704009000500	Station No. 4 - Hwy 101	154 L/s (2400 USGPM) Drainage Pump	2011	20	18	35	33	2	\$ 46,074	\$ 4,607	\$ 41,467	\$ 80,000	1	Field Audit	Good	1.0	2.0	2.0						
WWC-SPS-FLO-01	Buildings	Structure	Wastewater Collection	562704009071700.00	Station No. 5 - Florence St.	Pumping Station Building	1965	60	12	60	12	48	Controlled Asset		Controlled Asset	\$ 1,000,000	3	Field Audit	Fair	2.0	4.0	8.0						
WWC-SPS-FLO-02	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Pump No. 2	1978	20	0	35	0	35	\$ 8,065	\$ 8,065	\$ -	\$ 250,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-FLO-03	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Diesel Generator	1978	20	0	35	0	35	\$ 11,521	\$ 11,521	\$ -	\$ 300,000	5	Field Audit	Not in operation. Destroyed after storm	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-FLO-04	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	MCC Panel & Transfer Switch	1978	20	0	20	0	35	\$ -	\$ -	\$ -	\$ 350,000	5	Field Audit	Fair	4.0	3.0	12.0	Replace within 1 to 4 years	Added new asset class not on PSAB list				
WWC-SPS-FLO-05	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Automatic Bypass pump (5Hp)	1978	20	0	20	0	35	Controlled Asset	Controlled Asset	Controlled Asset	\$ 30,000	5	Field Audit	Poor	4.0	2.0	8.0						
WWC-SPS-FLO-06	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Portable By Pass Pump, 18 Hp	1997	20	4	20	4	16	\$ 6,918	\$ 5,534	\$ 1,384	\$ 30,000	4	Field Audit	Poor	3.0	2.0	6.0						
WWC-SPS-FLO-07	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Motor 1	2003	20	10	35	25	10	Controlled Asset		Controlled Asset	\$ 100,000	3	Field Audit	Fair	2.0	3.0	6.0						
WWC-SPS-FLO-08	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Pump No. 1	2004	20	11	35	26	9	\$ 26,637	\$ 11,987	\$ 14,650	\$ 250,000	4	Field Audit	Poor	3.0	3.0	9.0						
WWC-SPS-FLO-09	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Motor 2	2005	20	12	35	27	8	\$ 8,413	\$ 3,365	\$ 5,048	\$ 100,000	2	Field Audit	Fair	2.0	3.0	6.0						
WWC-SPS-FLO-10	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Pump 1 VFD	2005	20	12	20	12	8	\$ 12,019	\$ 4,808	\$ 7,211	\$ 150,000	4	Field Audit	Poor	3.0	3.0	9.0						
WWC-SPS-FLO-11	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	Pump 2 VFD	2005	20	12	20	12	8	\$ 8,413	\$ 3,365	\$ 5,048	\$ 150,000	4	Field Audit	Poor	3.0	3.0	9.0						
WWC-SPS-FLO-12	Mach/Equip	Heavy	Wastewater Collection	562704009071700	Station No. 5 - Florence St.	154 L/s (2400 USGPM) Drainage Pump	2011	20	18	35	33	2	\$ 46,074	\$ 4,607	\$ 41,467	\$ 80,000	1	Field Audit	Good	1.0	2.0	2.0						
WWC-SPS-BEL-01	Mach/Equip	Heavy	Wastewater Collection	562704009013500	Station No. 6 - Bellemare (First Ave.)	Pump No. 1	1977	20	0	35	0	36	\$ 4,317	\$ 4,317	\$ -	\$ 400,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years					
WWC-SPS-BEL-02	Mach/Equip	Heavy	Wastewater Collection	562704009013500	Station No. 6 - Bellemare (First Ave.)	Pump No. 2	1977	20	0	35	0	36				\$ 400,000	5	Field Audit	Very Poor	4.0	3.0	12.0	Replace within 1 to 4 years	Added new asset class not on PSAB list				
WWC-SPS-BEL-03	Mach/Equip	Heavy	Wastewater Collection	562704009013500	Station No. 6 - Bellemare (First Ave.)	Motor 2 100HP</																						